



ENERG

енергия · ενεργεια



Indoor unit
Outdoor unit

E*SE-**D
PUHZ-SW160YKA(-BS)



55 °C

35 °C



A⁺⁺

A⁺⁺



44 dB



78 dB

■ 10
■ **14**
■ 14
kW

■ 12
■ **15**
■ 15
kW



2019

811/2013

BH79V004H44

	For medium-temperature application.
--	-------------------------------------

		For medium-temperature application.																			For low-temperature application.																																		
		Medium-temperature application										Low-temperature application									Medium-temperature application										Low-temperature application																								
Outdoor unit	Indoor unit	Medium-temperature application	Seasonal space heating energy efficiency class	Water heating energy efficiency class	Rated heat output under average climate conditions kW	For space heating annual average climate conditions kWh	For water heating annual electricity consumption under average climate conditions kWh	Seasonal space heating energy efficiency under average climate conditions %	Water heating energy efficiency under average climate conditions %	Sound power level L _{WA} (indoor) dB	Work only during off-peak hours	Medium-temperature application										Low-temperature application										Medium-temperature application										Low-temperature application													
												Rated heat output under colder climate conditions kW	Rated heat output under warmer climate conditions kW	For space heating annual average climate conditions kWh	For space heating annual energy consumption under warmer climate conditions kWh	For water heating annual energy consumption under colder climate conditions kWh	For water heating annual energy consumption under warmer climate conditions kWh	Seasonal space heating energy efficiency under colder climate conditions %	Seasonal space heating energy efficiency under warmer climate conditions %	Water heating energy efficiency under colder climate conditions %	Water heating energy efficiency under warmer climate conditions %	Sound power level L _{WA} outdoor dB	Low-temperature application	Seasonal space heating energy efficiency class	Water heating energy efficiency class	Rated heat output under average climate conditions kW	For space heating annual average climate conditions kWh	For water heating annual average climate conditions kWh	Seasonal space heating energy efficiency under average climate conditions %	Water heating energy efficiency under average climate conditions %	Sound power level L _{WA} indoor dB	Work only during off-peak hours	Rated heat output under colder climate conditions kW	Rated heat output under warmer climate conditions kW	For space heating annual average climate conditions kWh	For space heating annual energy consumption under colder climate conditions kWh	For water heating annual energy consumption under warmer climate conditions kWh	For water heating annual energy consumption under colder climate conditions kWh	Seasonal space heating energy efficiency under colder climate conditions %	Seasonal space heating energy efficiency under warmer climate conditions %	Water heating energy efficiency under colder climate conditions %	Water heating energy efficiency under warmer climate conditions %	Sound power level L _{WA} outdoor dB												
PUHZ-SW50VKA-(BS)	EHS20C-""C2	✓	A++	A+	4.3	2689	740	125	146	40	-	4.0	4.3	3614	1378	878	643	101	157	122	168	63	✓	A++	A+	4.5	2138	740	163	146	40	-	4.2	4.5	2709	1095	878	643	141	207	122	168	63												
	ERS20C-""C2	✓	A++	A+	4.3	2669	740	128	146	40	-	4.0	4.3	3614	1378	878	643	103	161	122	168	63	✓	A++	A+	4.5	2138	740	167	146	40	-	4.2	4.5	2709	1095	878	643	145	214	122	168	63												
	EHS20C-""(W)	✓	A++	A	4.3	2689	1112	125	98	40	-	4.0	4.3	3614	1378	1373	1034	101	157	80	105	63	✓	A++	A	4.5	2138	1112	163	98	40	-	4.2	4.5	2709	1095	1373	1034	141	207	80	105	63												
	ERST20C-""(W)	✓	A++	A	4.3	2669	1112	128	98	40	-	4.0	4.3	3614	1378	1373	1034	103	161	80	105	63	✓	A++	A	4.5	2138	1112	167	98	40	-	4.2	4.5	2709	1095	1373	1034	145	214	80	105	63												
PUHZ-SW75VHA-(BS)	EHS20C-""C2	✓	A++	-	4.3	2689	-	125	-	40	-	4.0	4.3	3614	1378	-	-	101	157	-	-	63	✓	A++	-	4.5	2138	-	163	-	40	-	4.2	4.5	2709	1095	-	-	141	207	-	-	63												
	ERSD-""C	✓	A++	-	4.3	2669	-	128	-	40	-	4.0	4.3	3614	1378	-	-	103	161	-	-	63	✓	A++	-	4.5	2138	-	167	-	40	-	4.2	4.5	2709	1095	-	-	145	214	-	-	63												
	EHS20C-""(W)	✓	A++	A	7.1	4403	1050	127	103	40	-	6.3	7.1	5967	2389	1360	1055	100	153	80	112	68	✓	A++	A	7.2	3449	1050	165	103	40	-	6.4	7.2	4379	1596	1360	1055	139	231	80	112	68												
	ERST20C-""(W)	✓	A++	A	7.1	4403	1050	129	103	40	-	6.3	7.1	5967	2389	1360	1055	101	155	80	112	68	✓	A++	A	7.2	3449	1050	167	103	40	-	6.4	7.2	4379	1596	1360	1055	141	236	80	112	68												
	EHSC-""C	✓	A++	-	7.1	4403	-	127	-	40	-	6.3	7.1	5967	2389	-	-	100	153	-	-	68	✓	A++	-	7.2	3449	-	165	-	40	-	6.4	7.2	4379	1596	-	-	139	231	-	-	68												
	ERSC-""C	✓	A++	-	7.1	4403	-	129	-	40	-	6.3	7.1	5967	2389	-	-	101	155	-	-	68	✓	A++	-	7.2	3449	-	167	-	40	-	6.4	7.2	4379	1596	-	-	141	236	-	-	68												
	EHS20C-""C2	✓	A++	A+	7.1	4403	766	127	141	40	-	6.3	7.1	6048	2409	880	643	99	153	122	168	68	✓	A++	A+	7.2	3475	766	164	141	40	-	6.4	7.2	4463	1616	880	643	137	231	122	168	68												
PUHZ-SW100VHA-(BS)	ERST20C-""C2	✓	A++	A+	7.1	4403	766	129	141	40	-	6.3	7.1	6048	2409	880	643	101	155	122	168	68	✓	A++	A+	7.2	3475	766	167	141	40	-	6.4	7.2	4463	1616	880	643	141	236	122	168	68												
	EHS20C-""(W)	✓	A++	A	7.1	4403	1086	127	100	40	-	6.3	7.1	6048	2409	1377	1005	99	153	80	110	68	✓	A++	A	7.2	3475	1086	164	100	40	-	6.4	7.2	4463	1616	1377	1005	137	231	80	110	68												
	ERST20C-""(W)	✓	A++	A	7.1	4403	1086	129	100	40	-	6.3	7.1	6048	2409	1377	1005	101	155	80	110	68	✓	A++	A	7.2	3475	1086	167	100	40	-	6.4	7.2	4463	1616	1377	1005	141	236	80	110	68												
	EHS20C-""C2	✓	A++	-	7.1	4403	-	127	-	40	-	6.3	7.1	6048	2409	-	-	99	153	-	-	68	✓	A++	-	7.2	3475	-	164	-	40	-	6.4	7.2	4463	1616	-	-	137	231	-	-	68												
	ERSD-""C	✓	A++	-	7.1	4403	-	129	-	40	-	6.3	7.1	6048	2409	-	-	101	155	-	-	68	✓	A++	-	7.2	3475	-	167	-	40	-	6.4	7.2	4463	1616	-	-	141	236	-	-	68												
	EHS20C-""(W)	✓	A++	A	10.0	6331	1044	125	103	40	-	6.9	10.0	6129	3454	1330	973	106	149	82	113	70	✓	A++	A	10.4	5027	1044	164	103	40	-	7.2	10.4	4851	2502	1330	973	140	214	82	113	70												
	ERST20C-""(W)	✓	A++	A	10.0	6331	1044	127	103	40	-	6.9	10.0	6129	3454	1330	973	107	152	82	113	70	✓	A++	A	10.4	5027	1044	166	103	40	-	7.2	10.4	4851	2502	1330	973	143	219	82	113	70												
PUHZ-SW100YHA-(BS)	EHSC-""C	✓	A++	-	10.0	6331	-	125	-	40	-	6.9	10.0	6129	3454	-	-	106	149	-	-	70	✓	A++	-	10.4	5027	-	164	-	40	-	7.2	10.4	4851	2502	-	-	140	214	-	-	70												
	ERSC-""C	✓	A++	-	10.0	6331	-	127	-	40	-	6.9	10.0	6129	3454	-	-	107	152	-	-	70	✓	A++	-	10.4	5027	-	166	-	40	-	7.2	10.4	4851	2502	-	-	143	219	-	-	70												
	EHS20C-""(W)	✓	A++	A	10.0	6288	1044	125	103	40	-	6.9	10.0	6095	3425	1330	973	105	149	82	113	70	✓	A++	A	10.4	4993	1044	163	103	40	-	7.2	10.4	4805	2477	1330	973	140	214	82	113	70												
	ERST20C-""(W)	✓	A++	A	10.0	6288	1044	127	103	40	-	6.9	10.0	6095	3425	1330	973	107	152	82	113	70	✓	A++	A	10.4	4993	1044	166	103	40	-	7.2	10.4	4805	2477	1330	973	143	219	82	113	70												
	EHSC-""C	✓	A++	-	10.0	6288	-	125	-	40	-	6.9	10.0	6095	3425	-	-	105	149	-	-	70	✓	A++	-	10.4	4993	-	163	-	40	-	7.2	10.4	4805	2477	-	-	140	214	-	-	70												
	ERSC-""C	✓	A++	-	10.0	6288	-	127	-	40	-	6.9	10.0	6095	3425	-	-	107	152	-	-	70	✓	A++	-	10.4	4993	-	166	-	40	-	7.2	10.4	4805	2477	-	-	143	219	-	-	70												
	EHS20C-""(W)	✓	A++	A	12.0	7572	1109	125	99	40	-	8.1	12.0	8583	3958	1342	1053	110	157	82	104	72	✓	A++	A	12.9	6303	1109	162	99	40	-	8.4	12.9	5876	3006	1342	1053	136	222	82	104	72												
PUHZ-SW120VHA-(BS)	ERST20C-""(W)	✓	A++	A	12.0	7572	1109	127	99	40	-	8.1	12.0	8583	3958	1342	1053	112	159	82	104	72	✓	A++	A	12.9	6303	1109	164	99	40	-	8.4	12.9	5876	3006	1342	1053	139	226	82	104	72												
	EHSC-""C	✓	A++	-	12.0	7572	-	125	-	40	-	8.1	12.0	8583	3958	-	-	110	157	-	-	72	✓	A++	-	12.9	6303	-	162	-	40	-	8.4	12.9	5876	3006	-	-	136	222	-	-	72												
	ERSC-""C	✓	A++	-	12.0	7572	-	127	-	40	-	8.1	12.0	8583	3958	-	-	112	159	-	-	72	✓	A++	-	12.9	6303	-	164	-	40	-	8.4	12.9	5876	3006	-	-	139	226	-	-	72												
	EHS20C-""D	✓	A++	A+	12.0	7572	788	125	138	40	-	8.1	12.0	8583	3958	909	680	110	157	119	160	72	✓	A++	A+	12.9	6303	788	162	138	40	-	8.4	12.9	5876	3006	909	680	136	222	119	160	72												
	ERST20C-""D	✓	A++	A+	12.0	7572	788	127	138	40	-	8.1	12.0	8583	3958	909	680	112	159	119	160	72	✓	A++	A+	12.9	6303	788	164	138	40	-	8.4	12.9	5876	3006	909	680	139	226	119	160	72												
	EHS20C-""D	✓	A++	A	12.0	7572	1476	125	118	40	-	8.1	12.0	8583	3958	1901	1379	110	157	91	126	72	✓	A++	A	12.9	6303	1476	162	118	40	-	8.4	12.9	5876	3006	1901	1379	136	222	91	126	72												
	ERST30C-""D	✓	A++	A	12.0	7572	1476	127	118	40	-	8.1	12.0	8583	3958	1901	1379	112	159	91	126	72	✓	A++	A	12.9	6303	1476	164	118	40	-	8.4	12.9	5876	3006	1901	1379	139	226	91	126	72												
PUHZ-SW120YHA-(BS)	EHS20C-""D	✓	A++	-	12.0	7572	-	125	-	40	-	8.1	12.0	8583	3958	-	-	110	157	-	-	72	✓	A++	-	12.9	6303	-	162	-	40	-	8.4	12.9	5876	3006	-	-	136	222	-	-	72												
	ERSC-""C	✓	A++	-	12.0	7572	-	127	-	40	-	8.1	12.0	8583	3958	-	-	112	159	-	-	72	✓	A++	-	12.9	6303	-	164	-	40	-	8.4	12.9	5876	3006	-	-	139	226	-	-	72												
	EHS20C-""(W)	✓	A++	A	12.0	7533	1109	125	99	40	-	8.1	12.0	8519	3929	1342	1053	110	157	82	104	72	✓	A++	A	12.9	6259	1109	162	99	40	-	8.4	12.9	5828	2981	1342	1053	136	222	82	104	72												
	ERST20C-""(W)	✓	A++	A	12.0	7533	1109	127	99	40	-	8.1	12.0	8519	3929	1342	1053	112	159																																				

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	125	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	11.9	kW	Tj = - 7 °C	COPd	1.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	3.19	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	5.9	kW	Tj = + 7 °C	COPd	4.29	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	7.4	kW	Tj = +12 °C	COPd	6.32	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.83	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.70	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	2.2	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				
Capacity control	variable			Rated air flow rate, outdoors - 8400 m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA	
Annual energy consumption	Q _{HE}	8502	kWh	

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD. Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	η_s	161	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	13.5	kW	Tj = - 7 °C	COPd	2.57	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	8.2	kW	Tj = + 2 °C	COPd	4.15	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.3	kW	Tj = + 7 °C	COPd	5.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.08	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	2.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	7493	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	9.9	kW	Seasonal space heating energy efficiency	ηs	106	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.0	kW	Tj = - 7 °C	COPd	2.09	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	4.9	kW	Tj = + 2 °C	COPd	3.35	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.1	kW	Tj = + 7 °C	COPd	4.58	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.5	kW	Tj = +12 °C	COPd	6.35	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	9.4	kW	Tj = bivalent temperature	COPd	1.62	-
Tj = operation limit temperature	Pdh	9.4	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	9.9	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8806	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	11.8	kW	Seasonal space heating energy efficiency	η_s	139	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	7.2	kW	Tj = - 7 °C	COPd	2.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	5.3	kW	Tj = + 2 °C	COPd	4.30	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.4	kW	Tj = + 7 °C	COPd	5.45	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.07	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.2	kW	Tj = bivalent temperature	COPd	2.09	-
Tj = operation limit temperature	Pdh	11.2	kW	Tj = operation limit temperature	COPd	2.09	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	11.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8079	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	151	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	13.5	kW	Tj = + 2 °C	COPd	1.96	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	8.6	kW	Tj = + 7 °C	COPd	3.14	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.2	kW	Tj = +12 °C	COPd	5.39	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.74	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	η_s	212	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	15.3	kW	Tj = + 2 °C	COPd	3.18	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	9.8	kW	Tj = + 7 °C	COPd	4.81	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.6	kW	Tj = +12 °C	COPd	6.74	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				
Capacity control	variable			Rated air flow rate, outdoors - 8400 m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA	
Annual energy consumption	Q _{HE}	4596	kWh	

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	125	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	11.9	kW	Tj = - 7 °C	COPd	1.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	3.19	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	5.9	kW	Tj = + 7 °C	COPd	4.29	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	7.4	kW	Tj = +12 °C	COPd	6.32	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.83	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.70	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	2.2	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8502	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD. Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	ηs	161	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	13.5	kW	Tj = - 7 °C	COPd	2.57	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	8.2	kW	Tj = + 2 °C	COPd	4.15	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.3	kW	Tj = + 7 °C	COPd	5.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.08	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	2.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	7493	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	9.9	kW	Seasonal space heating energy efficiency	η_s	106	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature T _j			
T _j = - 7 °C	P _{dh}	6.0	kW	T _j = - 7 °C	COP _d	2.09	-
Degradation co-efficient (**)	C _{dh}	1.00	-				
T _j = + 2 °C	P _{dh}	4.9	kW	T _j = + 2 °C	COP _d	3.35	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = + 7 °C	P _{dh}	6.1	kW	T _j = + 7 °C	COP _d	4.58	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = +12 °C	P _{dh}	7.5	kW	T _j = +12 °C	COP _d	6.35	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = bivalent temperature	P _{dh}	9.4	kW	T _j = bivalent temperature	COP _d	1.62	-
T _j = operation limit temperature	P _{dh}	9.4	kW	T _j = operation limit temperature	COP _d	1.62	-
T _j = - 15 °C (if TOL < - 20 °C)	P _{dh}	-	kW	T _j = - 15 °C (if TOL < - 20 °C)	COP _d	-	-
Bivalent temperature	T _{biv}	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	9.9	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8806	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	11.8	kW	Seasonal space heating energy efficiency	η_s	139	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	7.2	kW	Tj = - 7 °C	COPd	2.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	5.3	kW	Tj = + 2 °C	COPd	4.30	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.4	kW	Tj = + 7 °C	COPd	5.45	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.07	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.2	kW	Tj = bivalent temperature	COPd	2.09	-
Tj = operation limit temperature	Pdh	11.2	kW	Tj = operation limit temperature	COPd	2.09	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	11.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8079	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	151	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	13.5	kW	Tj = + 2 °C	COPd	1.96	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	8.6	kW	Tj = + 7 °C	COPd	3.14	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.2	kW	Tj = +12 °C	COPd	5.39	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.74	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	EHSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	η_s	212	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	15.3	kW	Tj = + 2 °C	COPd	3.18	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	9.8	kW	Tj = + 7 °C	COPd	4.81	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.6	kW	Tj = +12 °C	COPd	6.74	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	126	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	11.9	kW	Tj = - 7 °C	COPd	1.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	3.19	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	5.9	kW	Tj = + 7 °C	COPd	4.29	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	7.4	kW	Tj = +12 °C	COPd	6.32	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.83	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.70	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	2.2	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8502	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD. Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	η_s	163	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	13.5	kW	Tj = - 7 °C	COPd	2.57	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	8.2	kW	Tj = + 2 °C	COPd	4.15	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.3	kW	Tj = + 7 °C	COPd	5.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.08	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	2.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				
Capacity control	variable			Rated air flow rate, outdoors - 8400 m ³ /h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA	
Annual energy consumption	Q _{HE}	7493	kWh	

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	9.9	kW	Seasonal space heating energy efficiency	η_s	107	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.0	kW	Tj = - 7 °C	COPd	2.09	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	4.9	kW	Tj = + 2 °C	COPd	3.35	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.1	kW	Tj = + 7 °C	COPd	4.58	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.5	kW	Tj = +12 °C	COPd	6.35	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	9.4	kW	Tj = bivalent temperature	COPd	1.62	-
Tj = operation limit temperature	Pdh	9.4	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	9.9	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				
Capacity control	variable			Rated air flow rate, outdoors - 8400 m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA	
Annual energy consumption	Q _{HE}	8806	kWh	

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	11.8	kW	Seasonal space heating energy efficiency	η_s	140	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	7.2	kW	Tj = - 7 °C	COPd	2.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	5.3	kW	Tj = + 2 °C	COPd	4.30	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.4	kW	Tj = + 7 °C	COPd	5.45	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.07	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.2	kW	Tj = bivalent temperature	COPd	2.09	-
Tj = operation limit temperature	Pdh	11.2	kW	Tj = operation limit temperature	COPd	2.09	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	11.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8079	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	152	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	13.5	kW	Tj = + 2 °C	COPd	1.96	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	8.6	kW	Tj = + 7 °C	COPd	3.14	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.2	kW	Tj = +12 °C	COPd	5.39	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.74	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	η_s	215	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	15.3	kW	Tj = + 2 °C	COPd	3.18	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	9.8	kW	Tj = + 7 °C	COPd	4.81	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.6	kW	Tj = +12 °C	COPd	6.74	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	126	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	11.9	kW	Tj = - 7 °C	COPd	1.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	3.19	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	5.9	kW	Tj = + 7 °C	COPd	4.29	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	7.4	kW	Tj = +12 °C	COPd	6.32	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	11.9	kW	Tj = bivalent temperature	COPd	1.83	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.70	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	2.2	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8502	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD. Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	η_s	163	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	13.5	kW	Tj = - 7 °C	COPd	2.57	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	8.2	kW	Tj = + 2 °C	COPd	4.15	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.3	kW	Tj = + 7 °C	COPd	5.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.08	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	2.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	7493	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	9.9	kW	Seasonal space heating energy efficiency	η_s	107	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.0	kW	Tj = - 7 °C	COPd	2.09	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	4.9	kW	Tj = + 2 °C	COPd	3.35	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.1	kW	Tj = + 7 °C	COPd	4.58	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.5	kW	Tj = +12 °C	COPd	6.35	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	9.4	kW	Tj = bivalent temperature	COPd	1.62	-
Tj = operation limit temperature	Pdh	9.4	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	9.9	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8806	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	11.8	kW	Seasonal space heating energy efficiency	η_s	140	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	7.2	kW	Tj = - 7 °C	COPd	2.83	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	5.3	kW	Tj = + 2 °C	COPd	4.30	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	6.4	kW	Tj = + 7 °C	COPd	5.45	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.7	kW	Tj = +12 °C	COPd	7.07	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	11.2	kW	Tj = bivalent temperature	COPd	2.09	-
Tj = operation limit temperature	Pdh	11.2	kW	Tj = operation limit temperature	COPd	2.09	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	11.8	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	8079	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	13.5	kW	Seasonal space heating energy efficiency	η_s	152	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature T _j			
T _j = - 7 °C	P _{dh}	-	kW	T _j = - 7 °C	COP _d	-	-
Degradation co-efficient (**)	C _{dh}	-	-				
T _j = + 2 °C	P _{dh}	13.5	kW	T _j = + 2 °C	COP _d	1.96	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = + 7 °C	P _{dh}	8.6	kW	T _j = + 7 °C	COP _d	3.14	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = +12 °C	P _{dh}	7.2	kW	T _j = +12 °C	COP _d	5.39	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = bivalent temperature	P _{dh}	11.9	kW	T _j = bivalent temperature	COP _d	1.74	-
T _j = operation limit temperature	P _{dh}	9.3	kW	T _j = operation limit temperature	COP _d	1.62	-
T _j = - 15 °C (if TOL < - 20 °C)	P _{dh}	-	kW	T _j = - 15 °C (if TOL < - 20 °C)	COP _d	-	-
Bivalent temperature	T _{biv}	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	8400	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW160YKA(-BS)
	Indoor unit:	ERSE-MED
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	15.3	kW	Seasonal space heating energy efficiency	ηs	215	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	15.3	kW	Tj = + 2 °C	COPd	3.18	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	9.8	kW	Tj = + 7 °C	COPd	4.81	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	7.6	kW	Tj = +12 °C	COPd	6.74	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	13.5	kW	Tj = bivalent temperature	COPd	2.57	-
Tj = operation limit temperature	Pdh	9.3	kW	Tj = operation limit temperature	COPd	1.62	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	8400	m³/h
Sound power level, indoors/outdoors	L _{WA}	45 / 78	dBA				
Annual energy consumption	Q _{HE}	4596	kWh				

For heat pump combination heater:

Declared load profile	-			Water heating energy efficiency	η_{wh}	-	%
Daily electricity consumption	Q _{elec}	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75YAA-SC
	Indoor unit:	ERST20D-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	yes	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	132	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.3	kW	Tj = - 7 °C	COPd	2.04	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	3.8	kW	Tj = + 2 °C	COPd	3.23	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = + 7 °C	Pdh	2.9	kW	Tj = + 7 °C	COPd	4.59	-
Degradation co-efficient (**)	Cdh	0.97	-				
Tj = +12 °C	Pdh	2.8	kW	Tj = +12 °C	COPd	6.10	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	2.04	-
Tj = operation limit temperature	Pdh	5.6	kW	Tj = operation limit temperature	COPd	1.37	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	1.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	2660	m³/h
Sound power level, indoors/outdoors	L _{WA}	41 / 58	dBA				
Annual energy consumption	Q _{HE}	4329	kWh				

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	145	%
Daily electricity consumption	Q _{elec}	3.420	kW/h				
Annual electricity consumption	AEC	752	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD. Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75YAA-SC
	Indoor unit:	ERST20D-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	yes	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	η_s	165	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.4	kW	Tj = - 7 °C	COPd	2.54	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	3.9	kW	Tj = + 2 °C	COPd	4.16	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = + 7 °C	Pdh	2.6	kW	Tj = + 7 °C	COPd	5.62	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = +12 °C	Pdh	3.1	kW	Tj = +12 °C	COPd	7.00	-
Degradation co-efficient (**)	Cdh	0.94	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.43	-
Tj = operation limit temperature	Pdh	5.6	kW	Tj = operation limit temperature	COPd	1.30	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	1.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	2660	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	41 / 58	dBA				
Annual energy consumption	Q _{HE}	3507	kWh				

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	145	%
Daily electricity consumption	Qelec	3.420	kW/h				
Annual electricity consumption	AEC	752	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75YAA-SC
	Indoor unit:	ERST20D-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	yes	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.0	kW	Seasonal space heating energy efficiency	η_s	109	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.6	kW	Tj = - 7 °C	COPd	2.37	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.2	kW	Tj = + 2 °C	COPd	3.24	-
Degradation co-efficient (**)	Cdh	0.97	-				
Tj = + 7 °C	Pdh	2.5	kW	Tj = + 7 °C	COPd	4.70	-
Degradation co-efficient (**)	Cdh	0.96	-				
Tj = +12 °C	Pdh	3.0	kW	Tj = +12 °C	COPd	6.74	-
Degradation co-efficient (**)	Cdh	0.95	-				
Tj = bivalent temperature	Pdh	5.7	kW	Tj = bivalent temperature	COPd	1.30	-
Tj = operation limit temperature	Pdh	5.6	kW	Tj = operation limit temperature	COPd	1.30	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	Psup	6.0	kW
Thermostat-off mode	P _{TO}	0.022	kW	Type of energy input			
Standby mode	P _{SB}	0.022	kW				
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	2660	m³/h
Sound power level, indoors/outdoors	L _{WA}	41 / 58	dBA				
Annual energy consumption	Q _{HE}	5169	kWh				

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	123	%
Daily electricity consumption	Qelec	3.990	kW/h				
Annual electricity consumption	AEC	877	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75YAA-SC
	Indoor unit:	ERST20D-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	yes	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.0	kW	Seasonal space heating energy efficiency	η_s	132	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature T _j			
T _j = - 7 °C	P _{dh}	3.6	kW	T _j = - 7 °C	COP _d	2.85	-
Degradation co-efficient (**)	C _{dh}	0.98	-				
T _j = + 2 °C	P _{dh}	2.4	kW	T _j = + 2 °C	COP _d	4.14	-
Degradation co-efficient (**)	C _{dh}	0.96	-				
T _j = + 7 °C	P _{dh}	2.6	kW	T _j = + 7 °C	COP _d	5.82	-
Degradation co-efficient (**)	C _{dh}	0.95	-				
T _j = +12 °C	P _{dh}	3.1	kW	T _j = +12 °C	COP _d	7.81	-
Degradation co-efficient (**)	C _{dh}	0.94	-				
T _j = bivalent temperature	P _{dh}	5.7	kW	T _j = bivalent temperature	COP _d	1.56	-
T _j = operation limit temperature	P _{dh}	5.6	kW	T _j = operation limit temperature	COP _d	1.30	-
T _j = - 15 °C (if TOL < - 20 °C)	P _{dh}	-	kW	T _j = - 15 °C (if TOL < - 20 °C)	COP _d	-	-
Bivalent temperature	T _{biv}	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	6.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	2660	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	41 / 58	dBA				
Annual energy consumption	Q _{HE}	4265	kWh				

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	123	%
Daily electricity consumption	Q _{elec}	3.990	kW/h				
Annual electricity consumption	AEC	877	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75YAA-SC
	Indoor unit:	ERST20D-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	yes	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	η_s	158	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature T _j			
T _j = - 7 °C	P _{dh}	-	kW	T _j = - 7 °C	COP _d	-	-
Degradation co-efficient (**)	C _{dh}	-	-				
T _j = + 2 °C	P _{dh}	7.1	kW	T _j = + 2 °C	COP _d	1.98	-
Degradation co-efficient (**)	C _{dh}	0.99	-				
T _j = + 7 °C	P _{dh}	4.6	kW	T _j = + 7 °C	COP _d	3.19	-
Degradation co-efficient (**)	C _{dh}	0.98	-				
T _j = +12 °C	P _{dh}	2.9	kW	T _j = +12 °C	COP _d	5.70	-
Degradation co-efficient (**)	C _{dh}	0.95	-				
T _j = bivalent temperature	P _{dh}	6.3	kW	T _j = bivalent temperature	COP _d	1.94	-
T _j = operation limit temperature	P _{dh}	5.6	kW	T _j = operation limit temperature	COP _d	1.30	-
T _j = - 15 °C (if TOL < - 20 °C)	P _{dh}	-	kW	T _j = - 15 °C (if TOL < - 20 °C)	COP _d	-	-
Bivalent temperature	T _{biv}	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	2660	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	41 / 58	dBA				
Annual energy consumption	Q _{HE}	2358	kWh				

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	161	%
Daily electricity consumption	Q _{elec}	3.080	kW/h				
Annual electricity consumption	AEC	678	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75YAA-SC
	Indoor unit:	ERST20D-***D
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	yes	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	η_s	225	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	3.13	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.6	kW	Tj = + 7 °C	COPd	4.79	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	3.1	kW	Tj = +12 °C	COPd	7.57	-
Degradation co-efficient (**)	Cdh	0.94	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.43	-
Tj = operation limit temperature	Pdh	5.6	kW	Tj = operation limit temperature	COPd	1.30	-
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.022	kW	Rated heat output (*)	P _{sup}	0.0	kW
Thermostat-off mode	P _{TO}	0.022	kW				
Standby mode	P _{SB}	0.022	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	2660	m ³ /h	
Sound power level, indoors/outdoors	L _{WA}	41 / 58	dBA				
Annual energy consumption	Q _{HE}	2358	kWh				

For heat pump combination heater:

Declared load profile	L			Water heating energy efficiency	η_{wh}	161	%
Daily electricity consumption	Q _{elec}	3.080	kW/h				
Annual electricity consumption	AEC	678	kW/h				

Contact details

MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	129	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.3	kW	Tj = - 7 °C	COPd	1.95	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	3.8	kW	Tj = + 2 °C	COPd	3.24	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.7	kW	Tj = + 7 °C	COPd	4.46	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	4.3	kW	Tj = +12 °C	COPd	5.89	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	1.95	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.35	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.9	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	4403	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD.				Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.			

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	ηs	167	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.4	kW	Tj = - 7 °C	COPd	2.98	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	3.9	kW	Tj = + 2 °C	COPd	4.04	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.9	kW	Tj = + 7 °C	COPd	5.55	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.6	kW	Tj = +12 °C	COPd	7.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.98	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.9	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	3449	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.3	kW	Seasonal space heating energy efficiency	ηs	101	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.8	kW	Tj = - 7 °C	COPd	2.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.3	kW	Tj = + 2 °C	COPd	2.93	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.7	kW	Tj = + 7 °C	COPd	4.32	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.4	kW	Tj = +12 °C	COPd	6.23	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.0	kW	Tj = bivalent temperature	COPd	1.28	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	6.3	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	5967	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.4	kW	Seasonal space heating energy efficiency	ηs	141	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.9	kW	Tj = - 7 °C	COPd	3.55	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.4	kW	Tj = + 2 °C	COPd	3.91	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.9	kW	Tj = + 7 °C	COPd	5.54	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.6	kW	Tj = +12 °C	COPd	7.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.1	kW	Tj = bivalent temperature	COPd	1.28	-
Tj = operation limit temperature	Pdh	6.1	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	6.4	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	4379	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	155	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.1	kW	Tj = + 2 °C	COPd	1.99	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.6	kW	Tj = + 7 °C	COPd	3.20	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.2	kW	Tj = +12 °C	COPd	5.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	1.85	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	2389	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	ηs	236	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	2.87	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.7	kW	Tj = + 7 °C	COPd	5.83	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.5	kW	Tj = +12 °C	COPd	7.05	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.98	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	2389	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-MEC
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	129	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.3	kW	Tj = - 7 °C	COPd	1.95	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	3.8	kW	Tj = + 2 °C	COPd	3.24	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.7	kW	Tj = + 7 °C	COPd	4.46	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	4.3	kW	Tj = +12 °C	COPd	5.89	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	1.95	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.35	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.9	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	4403	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD.				Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.			

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-MEC
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	ηs	167	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.4	kW	Tj = - 7 °C	COPd	2.98	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	3.9	kW	Tj = + 2 °C	COPd	4.04	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.9	kW	Tj = + 7 °C	COPd	5.55	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.6	kW	Tj = +12 °C	COPd	7.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.98	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.9	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	3449	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-MEC
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.3	kW	Seasonal space heating energy efficiency	ηs	101	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.8	kW	Tj = - 7 °C	COPd	2.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.3	kW	Tj = + 2 °C	COPd	2.93	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.7	kW	Tj = + 7 °C	COPd	4.32	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.4	kW	Tj = +12 °C	COPd	6.23	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.0	kW	Tj = bivalent temperature	COPd	1.28	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	6.3	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	5967	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-MEC
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.4	kW	Seasonal space heating energy efficiency	ηs	141	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.9	kW	Tj = - 7 °C	COPd	3.55	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.4	kW	Tj = + 2 °C	COPd	3.91	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.9	kW	Tj = + 7 °C	COPd	5.54	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.6	kW	Tj = +12 °C	COPd	7.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.1	kW	Tj = bivalent temperature	COPd	1.28	-
Tj = operation limit temperature	Pdh	6.1	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	6.4	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	4379	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-MEC
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	155	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.1	kW	Tj = + 2 °C	COPd	1.99	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.6	kW	Tj = + 7 °C	COPd	3.20	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.2	kW	Tj = +12 °C	COPd	5.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	1.85	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	2389	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details			
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.			

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSC-MEC
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	no	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	ηs	236	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	2.87	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.7	kW	Tj = + 7 °C	COPd	5.83	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.5	kW	Tj = +12 °C	COPd	7.05	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.98	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	2389	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSD-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	129	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.3	kW	Tj = - 7 °C	COPd	1.95	-
Degradation co-efficient (**)	Cdh	1.00	-				
Tj = + 2 °C	Pdh	3.8	kW	Tj = + 2 °C	COPd	3.24	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.7	kW	Tj = + 7 °C	COPd	4.46	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = +12 °C	Pdh	4.3	kW	Tj = +12 °C	COPd	5.89	-
Degradation co-efficient (**)	Cdh	0.98	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	1.95	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.35	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.9	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	4403	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD.				Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.			

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSD-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	average climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	ηs	167	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	6.4	kW	Tj = - 7 °C	COPd	2.98	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	3.9	kW	Tj = + 2 °C	COPd	4.04	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.9	kW	Tj = + 7 °C	COPd	5.55	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.6	kW	Tj = +12 °C	COPd	7.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.98	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.9	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	3449	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSD-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.3	kW	Seasonal space heating energy efficiency	ηs	101	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.8	kW	Tj = - 7 °C	COPd	2.22	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.3	kW	Tj = + 2 °C	COPd	2.93	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.7	kW	Tj = + 7 °C	COPd	4.32	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.4	kW	Tj = +12 °C	COPd	6.23	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.0	kW	Tj = bivalent temperature	COPd	1.28	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	6.3	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	5967	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSD-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	colder climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	6.4	kW	Seasonal space heating energy efficiency	ηs	141	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.9	kW	Tj = - 7 °C	COPd	3.55	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 2 °C	Pdh	2.4	kW	Tj = + 2 °C	COPd	3.91	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	3.9	kW	Tj = + 7 °C	COPd	5.54	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.6	kW	Tj = +12 °C	COPd	7.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.1	kW	Tj = bivalent temperature	COPd	1.28	-
Tj = operation limit temperature	Pdh	6.1	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-20	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	6.4	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	4379	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSD-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	medium-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.1	kW	Seasonal space heating energy efficiency	ηs	155	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.1	kW	Tj = + 2 °C	COPd	1.99	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.6	kW	Tj = + 7 °C	COPd	3.20	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.2	kW	Tj = +12 °C	COPd	5.50	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.3	kW	Tj = bivalent temperature	COPd	1.85	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	2389	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.

Model(s):	Outdoor unit:	PUHZ-SW75VHA(-BS)
	Indoor unit:	ERSD-***C
Air-to-water heat pump:	yes	
Water-to-water heat pump:	no	
Brine-to-water heat pump:	no	
Low-temperature heat pump:	no	
Equipped with a supplementary heater:	yes	
Heat pump combination heater:	no	
Parameters for	low-temperature application.	
Parameters for	warmer climate conditions.	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output (*)	Prated	7.2	kW	Seasonal space heating energy efficiency	ηs	236	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	-	kW	Tj = - 7 °C	COPd	-	-
Degradation co-efficient (**)	Cdh	-	-				
Tj = + 2 °C	Pdh	7.2	kW	Tj = + 2 °C	COPd	2.87	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = + 7 °C	Pdh	4.7	kW	Tj = + 7 °C	COPd	5.83	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = +12 °C	Pdh	4.5	kW	Tj = +12 °C	COPd	7.05	-
Degradation co-efficient (**)	Cdh	0.99	-				
Tj = bivalent temperature	Pdh	6.4	kW	Tj = bivalent temperature	COPd	2.98	-
Tj = operation limit temperature	Pdh	6.0	kW	Tj = operation limit temperature	COPd	1.28	-
Tj = – 15 °C (if TOL < – 20 °C)	Pdh	-	kW	Tj = – 15 °C (if TOL < – 20 °C)	COPd	-	-
Bivalent temperature	Tbiv	-7	°C	Operation limit temperature	TOL	-20	°C
				Heating water operating limit temperature	WTOL	60	°C
Power consumption in modes other than active mode				Supplementary heater			
Off mode	P _{OFF}	0.015	kW	Rated heat output (*)	Psup	0.0	kW
Thermostat-off mode	P _{TO}	0.015	kW				
Standby mode	P _{SB}	0.015	kW	Type of energy input			
Crankcase heater mode	P _{CK}	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	3300	m ³ /h
Sound power level, indoors/outdoors	L _{WA}	40 / 68	dBA				
Annual energy consumption	Q _{HE}	2389	kWh				

For heat pump combination heater:							
Declared load profile	-			Water heating energy efficiency	ηwh	-	%
Daily electricity consumption	Qelec	-	kW/h				
Annual electricity consumption	AEC	-	kW/h				

Contact details							
MITSUBISHI ELECTRIC AIR CODITIONING SYSTEM EUROPE LTD Nettlehill Road, Houston Industrial Estate, Livingston, EH54 5EQ, Scotland, U.K.							

(*) For heat pump space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).
(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0,9.